

**From:** Mike Kopar <[mike.kopar@psiusa.com](mailto:mike.kopar@psiusa.com)>  
**Sent:** Friday, February 12, 2016 8:34 AM  
**To:** Jim Perlik  
**Subject:** qtrak

Jim:

Attached are the print outs for the data collected. There is a summary page at the front that is really all you need to see that the CO2 levels were all <1000 PPM.

Looking at test 2 (1-29 thru 2-4), there were times when the temp did get warm (near 80). RH levels were < 20% on 1-29, and slowly started to rise to 30% through 1/31. They dropped below 20% on 2/2. RH levels were in the 30s and even 40s on 2-3. There was some fluctuation there. CO2 and CO were good

Test 3 (2-5 thru 2-9 showed similar fluctuations, however RH did not get to 30% and lows were in the single digits. That is pretty low. CO2 was fine. CO was minimal.

**Michael Kopar, CIE**  
Project Manager  
**Professional Service Industries, Inc. (PSI)**  
850 Poplar Street  
Pittsburgh, PA 15220  
(412) 922-4001 x383 (office)  
(724) 630-1713 (mobile)  
(412) 922-4043 (fax)  
[mike.kopar@psiusa.com](mailto:mike.kopar@psiusa.com)